

WATER ANALYSIS REPORT



District Level Water Analysis Laboratory

U. P. Jai Nigam (Rural), Kolbaj Bahadur (Pragati Nagar),

NABL T-8677

Azamgarh- 276001

Report No.: C/AZM/01		Date:11.06.2025		No. of Pages: 1	
Customer Details					
Office Name and Address		Anwar Public School Godhiana Azamgarh			
Ref. Letter No. & Date		NA			
Basic Details of Sample					
District	Azamgarh	Block	Pawai		
Gram Panchayat	Godhiana	Village	Godhiana		
Habitation	Main	Location	Anwar Public School Godhiana Azamgarh		
Water Source	R.O (Drinking Water)	Sample Code	C/AZM/JINE/01		
Quantity of Sample	1000 mL (Normal), 500 mL	Sampling date	09.06.2025		
Sample Received Date	09.06.2025	Sample collected by	Anwar Public School Godhiana (Manager)		
Sampling Method Used	NA	Sample Depositor	Anwar Public School Godhiana (Manager)		
Analysis Start Date	09.06.2025	Analysis Completion Date	11.06.2025		

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)	Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit
1	1 Taste		4	5
2	2 Odour	Agreeable	Agreeable/Not Agree.	Agreeable/Not Agree.
3	3 Turbidity (NTU) **	1.21	Agreeable	Agreeable
4	4 pH **	7.12	6.5-8.5	6.5-8.5
5	5 Colour (Platzen units) **	0.00	5	15
6	6 Total Dissolved Solids, mg/l **	152	500	2000
7	7 Chloride (as Cl), mg/l **	92	250	1000
8	8 Total Alkalinity, (as CaCO ₃) mg/l **	102	200	600
9	9 Total Hardness, (as CaCO ₃) mg/l **	112	200	600
10	10 Calcium (as Ca), mg/l **	32	75	200
11	11 Magnesium (as Mg), mg/l **	44	30	100
12	12 Sulphate (as SO ₄), mg/l **	11.23	200	400
13	13 Nitrate (as NO ₃), mg/l **	2.89	45	No relaxation
14	14 Fluoride (as F), mg/l **	BDL(0.482)	1.00	1.50
15	15 Iron (as Fe), mg/l **	BDL(0.002)	1.00	No relaxation
16	16 Arsenic	BDL(0.001)	0.010	0.010
17	17 Es.coli	0.0	0.0	0.0
18	18 Total Coliform	0.0	0.0	0.0

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA-Not Analysed

- Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permissible Limit are written in bold.
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
7. Sample is not Collected by Lab. 8. ** Indicates Parameters are NABL Accredited.

ARVIND KANCHALURVEDI
(Report prepared by)

Laboratory Contact Details:

Email: sandeepkumar181092@gmail.com

Mobile No: 8934550472



*****END OF THE ANALYSIS REPORT*****

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. -C/AZM/01

Dated:11.06.2025

It is certified that an inspection team headed by **Satyendra Kumar (A.E)**, District Level Water Analysis Laboratory, Azamgarh (Name of officers with designation) from **UP Jal Nigam (Rural) Azamgarh** (Name of Department/office) Inspected the **Anwar Public School Godhana, Azamgarh Uttar Pradesh** (Name &Address of the school) on **09.06.2025**(Date of inspection) and on the basis of water test report (Attached) Report no: **C/AZM/JUNE/01** dated **11.06.2025** of **District Level Water Analysis Laboratory, Azamgarh (PHED)** lab certified that the **Anwar Public School Godhana Azamgarh Uttar Pradesh** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T.Govt.

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory,Azamgarh.

Signature with Seal.....
Name Satyendra Kumar
Designation..... A. E
Name & Address of the office/Department

**Uttar Pradesh Jal Nigam Rural, kolbaj Bahadur
(Pragati Nagar) Azamgarh 276001**

To

Director,
Anwar Public School
Godhana, Azamgarh Uttar Pradesh
(Name& Address of the institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.